

CARD DB GENERAL INFORMATIONRecording date: **2/3/09**Type **Hotel**Name **HOTEL SEMPIONE**Category **3 STARS**Address **VIA NAZIONALE, 15**Town **FIRENZE**Province **FIRENZE**Telephone **055-212462 055-283012**Fax **055-212463**E-mail **info@hotelsempione.info**Internet **www.hotelsempione.info**Hours of public service **24 ore**Closing day or closing time **december 20 to 27**Person in charge of: **Giorgio Neri**Qualification **Executive Manager**Position **town center**Surrounding land **level roads**Height of place a.s.l., mt. **50**

Spoken languages?:

Italian**English****Spanish****French****German****Portuguese**

Services offered by the structure:

Generic room**Breakfast room**

Transport towards structure

Urban bus

Distance from
nearest stop, mt. **100**

Transport towards structure

Distance from
nearest stop, mt.

Are there generic plans of the structure? **No**

Are there tactile plans of the structure? **No**

Are there generic brochures of the structure? **Yes**

Are there printed information brochures in Braille? **No**

Information availability on: **Sound record**

Available transport for internal or external mobility: **None**

rents wheelchairs and crutches
l'Humanitas noleggia carrozine e stampelle

The following payment is accepted

All

CARD DB_ACCOMODATION STRUCTURE

0015

HOTEL SEMPIONE

Period when open: Annual

Service method: B&B

Is Room Service available? Yes

Are rooms declared accessible by the manager? Yes

How many? 2

Are rooms declared anti-allergic by the manager? No

How many?

There are menus for:

Which public structures are present in the town or in the town closest by?

Health Structures within about 5 km

Emergency room
Ophthalmology
Neuropsychiatry

Service structures in the area

Tourist information office

Service structures in the provincial area

Are there emergency exits? Yes

The alarm is: Acoustic

Notes: In case of call from international cellphone all phone numbers require international prefix 0039.

- Hospital: Ospedale di S.M. Nuova P.za S.M. Nuova, 1 tel. 055-27.58.1
- First Aid: Misericordia di Firenze P.za Duomo, 20 tel. 055-23939
- Eyes Surgeon: Oculista Laganà via dei Martelli, 8 tel. 055-23.81.699

- Touristic Informations: P.za della Stazione tel. 055-212245
- Touristic Informations: Borgo Santa Croce, 29 tel. 055-23.40.444
- Touristic Informations: Via Manzoni, 16 tel. 055-23.32.0

- Car Repair special equipment: Autofficina, via Mariti, 53 tel 055-35.18.93
- Special equipment car repair and rental - Autofficina Poggesi,
via di Collodi, 10/20 tel. 339-40.40.759
- Car Rental: Autonoleggio Auto via de' Cattani, 23 tel. 055-30.24.436
- Bike and scooter rental: via S. Zanobi, 120/r tel. 055-48.89.92

CARD DB_PARKING LOT / CAR PARK**HOTEL SEMPIONE**

Type of parking lot: Garage
 Paying
 Covered

Is there an intercom system?

Type?

Height, cm

Obstacles:

The distance is mt

Type of path:

Type of pavement:

Possible difficulties encountered along the way:

Is it connected directly to the structure?

By:

Are there direction signs?

Are tactile guides present?

Notes: The hotel has an agreement with a paying garage parking service that picks-up/return the car on demand.
 The service is made by the hotel staff.
 The hotel has two reserved places at S. M. Novella parking.

LEVEL OF SATISFACTION OF NEEDS

Family with children in stroller/pram	Good
Obese person or pregnant woman	Good
Elderly, lame, heart patient	Good
Deaf or hearing impaired person	Good
Blind or visually impaired person	Good
Person in wheel-chair with companion	Good
Person in wheel-chair alone	Good

CARD DB_ENTRANCE

0015

HOTEL SEMPIONE

Entrance: Principal

Width, cm 108

Are there stairs? Yes

How many? 1

Are they chromatically marked? No

Are there any aids to bypass the stairs? Yes

Which? stairs

Are there chromatic-optical contrasts?

What do they point out?

Is there an intercom system? bell

Height cm 131

Obstacles:

Type of entrance door opening: revolving

Conditions: manual

Notes:

To overcome the steps an occasional ramp is available.

LEVEL OF SATISFACTION OF NEEDS

Family with children in stroller/pram	Partial
Obese person or pregnant woman	Partial
Elderly, lame, heart patient	Partial
Deaf or hearing impaired person	Good
Blind or visually impaired person	Partial
Person in wheel-chair with companion	Good
Person in wheel-chair alone	Partial

0015

CARD DB_RECEPTION

HOTEL SEMPIONE

Function noted: hotel

Counter height, cm 110

Narrowest passage, cm

Steps? No

How many grouped together?

How many isolated?

Presence of obstacles for mobility? No

Yes, what are they :

Systems for dialogue, useful information: Verbal

Notes:

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Partial

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Partial

0015

CARD DB_INTERNAL PATHWAYS

HOTEL SEMPIONE

MOBILITY OR DIRECTION PROBLEMS NOTICED ON THE PATHWAYS

FROM:

Elevator entrance

TO:

Breakfast room

PROBLEMS?

Type of obstacle:

Three steps for a total high of 51 cm.

Notes:

LEVEL OF SATISFACTION OF NEEDS

Family with children in stroller/pram	Partial
Obese person or pregnant woman	Partial
Elderly, lame, heart patient	Partial
Deaf or hearing impaired person	Good
Blind or visually impaired person	Partial
Person in wheel-chair with companion	Partial
Person in wheel-chair alone	Partial

Present? Yes

Is a service key necessary? No

Where is the key kept ?

Instructions for use:

Connected from: ground

To: thord

Interior width, cm 120

Entrance, cm 73

Interior depth, cm 80

Entrance type: Single door

Interior push-button panel: In Braille and relief

Maximum height of cm 131

Acoustic signal of arrival at floor: Acoustic and visual

Is an intercom or emergency button present? Yes

Height, cm 131

Notes:

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Good

CARD DB_STAIR

0015

HOTEL SEMPIONE

Are stairs present? Yes

Width, cm 122

Flight of stairs n. 3

Total number of stairs n. 81

Connecting from: ground

To: fourth

Is there a hand rail: To the right

Notes: The stairway is inside of the hotel and it's the only emergency exit.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Partial

Blind or visually impaired person Partial

Person in wheel-chair with companion

Person in wheel-chair alone

0015

CARD DB_RAMP

HOTEL SEMPIONE

Are one or more ramps present? Yes

How many? 1

Width, cm

Length, cm 230

Surpassed difference in height, cm 51

Gradient: 22,2 %

Connected from: first floor

to: Mezzanine floor (first)

Equipped with handrail : No

Notes: Aluminum removable ramp.

LEVEL OF SATISFACTION OF NEEDS

Family with children in stroller/pram	Partial
Obese person or pregnant woman	Partial
Elderly, lame, heart patient	Partial
Deaf or hearing impaired person	Partial
Blind or visually impaired person	Partial
Person in wheel-chair with companion	Partial
Person in wheel-chair alone	Scarce

HOTEL SEMPIONE

Type: hotel

Number - Name: 36

Situated on floor: terzo

Type of room: Twin

Anti-allergenic room? No

Yes:

The room is: No smoking

Width of entrance door cm 80

Internal door, cm 91

Other:

Is there sufficient space for wheel-chair rotation ? Yes

Other: bed to be removed

Narrowest passage, cm

Description:

Presence of carpeting? No

Are there internal stairs? No

Where?

Is it possible to move the bed? Yes

Bed height, cm 58

Is it possible to modify bed height? No

from cm to cm

Is it possible to move the furniture? Yes
Si

Is there a bathroom in the room? Yes

Bath on the floor at a distance of mt

Is there a telephone? Yes

Alarm system: no

Are there obstacles along the passageway from the room to the emergency exit? No

Which?

Where do the escape routes lead to: inaccessible emergency exit

Notes: Accessible rooms numbers are: 26, 36 similar in disposition and dimensions.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies	Partial
Family with children in stroller/pram	Good
Obese person or pregnant woman	Good
Elderly, lame, heart patient	Good
Deaf or hearing impaired person	Partial
Blind or visually impaired person	Partial
Person in wheel-chair with companion	Good
Person in wheel-chair alone	Good

CARD DB_WC/BATHROOM/RESTROOM**HOTEL SEMPIONE**

Service:

In: room

Number - name: 36

Situated on floor: third

Anteroom? No

Entrance door, cm

Basin?

Type:

Type of basin faucet:

Space in front of the faucet, cm

Presence of: Bathroom

Entrance door, cm 80

Basin? Yes

Type: suspended

Type of basin faucet: lever

Space in front of the faucet, cm 150

Type of toilet: floor toilet with external hand shower

Space in front of toilet, cm 160

Space to the right of toilet, cm 28

Space to the left of toilet, cm 125

Height of toilet, cm 52

Bidet? No

Handles to the right of toilet? No

Handles to the left of toilet? Yes

Shower? Yes

Type of shower:

Shower provided with seat? Yes

Type: removable

Shower provided with handles? Yes

Bathtub? No

Type:

Provided with internal seat?

Provided with handles?

Provided with lifter?

Model:

Notes:

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Good

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Partial

CARD DB_WC/BATHROOM/RESTROOM**HOTEL SEMPIONE**

Service:

In: public

Number - name:

Situated on floor:

Anteroom? No

Entrance door, cm

Basin?

Type:

Type of basin faucet:

Space in front of the faucet, cm

Presence of: Restroom

Entrance door, cm 60

Basin? Yes

Type: sospeso
suspended

Type of basin faucet: pedal

Space in front of the faucet, cm 93

Type of toilet:

Space in front of toilet, cm

Space to the right of toilet, cm

Space to the left of toilet, cm

Height of toilet, cm

Bidet?

Handles to the right of toilet?

Handles to the left of toilet?

Shower?

Type of shower:

Shower provided with seat?

Type:

Shower provided with handles?

Bathtub?

Type:

Provided with internal seat?

Provided with handles?

Provided with lifter?

Model:

Notes: Not accessible.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Partial

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Partial

Person in wheel-chair alone Scarce

CARD DB_ROOMS/SERVICES

0015

HOTEL SEMPIONE

Type: hotel

Name of room: Bar area

Hall / service is located on floor: ground floor

Number of seats n. 6

Entrance, cm

Narrowest passage, cm

Is there sufficient space for wheel-chair rotation? Yes

Are there reserved seats? no

How many?

Relations with the public are:

Height of buffet, cm

Height of counter, cm 110

Notes: Bar and internet point area are a little narrow

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Partial

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Partial

Person in wheel-chair alone Partial

CARD DB_ROOMS/SERVICES

0015

HOTEL SEMPIONE

Type: hotel

Name of room: Tv room

Hall / service is located on floor: ground floor

Number of seats n. 6

Entrance, cm 150

Narrowest passage, cm

Is there sufficient space for wheel-chair rotation? Yes

Are there reserved seats? no

How many?

Relations with the public are:

Height of buffet, cm

Height of counter, cm 110

Notes:

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Partial

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Partial

Person in wheel-chair alone Partial

CARD DB_ROOMS/SERVICES

0015

HOTEL SEMPIONE

Type: hotel

Name of room: Breakfast room

Hall / service is located on floor: first

Number of seats n. 31

Entrance, cm 99

Narrowest passage, cm

Is there sufficient space for wheel-chair rotation? Yes

Are there reserved seats? no

How many?

Relations with the public are:

Height of buffet, cm 77 / 113 / 140

Height of counter, cm 100/135

Notes: Breakfast is served on the table, the buffet is on different floors.
To access the breakfast room there are three steps to overcome with a aluminum removable ramp with 20% slope.
Tables in the corridor to access the room can be removed in case of disabled passing.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies Partial

Person with allergies

Family with children in stroller/pram Partial

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person

Blind or visually impaired person Partial

Person in wheel-chair with companion Partial

Person in wheel-chair alone Partial