

CARD DB GENERAL INFORMATION

Recording date: 2/3/09

Type Hotel

Name HOTEL CELLAI

Category 3 STARS

Address VIA 27 SETTEMBRE, 14

Town FIRENZE

Province FIRENZE

Telephone 055-489291

Fax 055-470387

E-mail info@hotelcellai.it

Internet

Hours of public service 24 hours

Closing day or closing time no

Person in charge of: Francesco Cavallo

Qualification Executive manager

Position town center

Surrounding land level roads

Height of place a.s.l., mt. 50

- Spoken languages?:
- Italian
- English
- Spanish
- French
- German
- Japanese

- Services offered by the structure:
- Meeting rooms
- Waiting room
- Breakfast room
- TV room

Transport towards structure	Urban bus	Distance from nearest stop, mt.	100
Transport towards structure		Distance from nearest stop, mt.	
Transport towards structure		Distance from nearest stop, mt.	
Transport towards structure		Distance from nearest stop, mt.	

Are there generic plans of the structure? No

Are there tactile plans of the structure? No

Are there generic brochures of the structure? Yes

Are there printed information brochures in Braille? No

Information availability on: No support

Available transport for internal or external mobility: Bicycle

The following payment is accepted

All

CARD DB_ACCOMODATION STRUCTURE

0003

HOTEL CELLAI

Period when open: Annual

Service method: B&B

Is Room Service available? Yes

Are rooms declared accessible by the manager? Yes

How many? 6

Are rooms declared anti-allergic by the manager? No

How many?

There are menus for:

Which public structures are present in the town or in the town closest by?

Health Structures within about 5 km

Service structures in the area

Tourist information office

Service structures in the provincial area

Are there emergency exits? Yes

The alarm is: Visual and Acoustic

Notes: In case of call from international cellphone all phone numbers require international prefix 0039.

- Hospital: Ospedale di S.M. Nuova P.za S.M. Nuova, 1 tel. 055-27.58.1
- First Aid: Misericordia di Firenze P.za Duomo, 20 tel. 055-23939
- Eyes Surgeon: Oculista Laganà via dei Martelli, 8 tel. 055-23.81.699

- Touristic Informations: P.za della Stazione tel. 055-212245
- Touristic Informations: Borgo Santa Croce, 29 tel. 055-23.40.444
- Touristic Informations: Via Manzoni, 16 tel. 055-23.32.0

- Car Repair special equipment: Autofficina, via Mariti, 53 tel 055-35.18.93
- Special equipment car repair and rental - Autofficina Poggesi,
via di Collodi, 10/20 tel. 339-40.40.759
- Car Rental: Autonoleggio Auto via de' Cattani, 23 tel. 055-30.24.436
- Bike and scooter rental: via S. Zanobi, 120/r tel. 055-48.89.92

CARD DB_PARKING LOT / CAR PARK

HOTEL CELLAI

Type of parking lot: Garage
Paying
Covered

Is there an intercom system?

Type?

Height, cm

Obstacles:

The distance is mt

Type of path:

Type of pavement:

Possible difficulties encountered along the way:

Is it connected directly to the structure?

By:

Are there direction signs?

Are tactile guides present?

Notes: The hotel has an agreement with a paying garage parking service that picks-up/return the car on demand.
The service is made by the hotel staff.

LEVEL OF SATISFACTION OF NEEDS

Family with children in stroller/pram	Good
Obese person or pregnant woman	Good
Elderly, lame, heart patient	Good
Deaf or hearing impaired person	Good
Blind or visually impaired person	Good
Person in wheel-chair with companion	Good
Person in wheel-chair alone	Good

0003

CARD DB_INTERNAL PATHWAYS

HOTEL CELLAI

MOBILITY OR DIRECTION PROBLEMS NOTICED ON THE PATHWAYS

FROM:

TO:

PROBLEMS?

Type of obstacle:

Notes:

LEVEL OF SATISFACTION OF NEEDS

Family with children in stroller/pram	Partial
Obese person or pregnant woman	Good
Elderly, lame, heart patient	Partial
Deaf or hearing impaired person	Good
Blind or visually impaired person	Partial
Person in wheel-chair with companion	Good
Person in wheel-chair alone	Partial

CARD DB_ENTRANCE

0003

Entrance:

Width, cm

Are there stairs? no

How many?

Are they chromatically marked?

Are there any aids to bypass the stairs?

Which?

Are there chromatic-optical contrasts?

What do they point out?

Is there an intercom system?

Height cm

Obstacles:

Type of entrance door opening: revolving

Conditions: manual

Notes:

Sidewalk next to the building is accessible.

LEVEL OF SATISFACTION OF NEEDS

Family with children in stroller/pram	Good
Obese person or pregnant woman	Good
Elderly, lame, heart patient	Good
Deaf or hearing impaired person	Good
Blind or visually impaired person	Partial
Person in wheel-chair with companion	Good
Person in wheel-chair alone	Partial

CARD DB_ENTRANCE

0003

HOTEL CELLAI

Entrance: Reserved for disabled people

Width, cm 120

Are there stairs? no

How many?

Are they chromatically marked?

Are there any aids to bypass the stairs?

Which?

Are there chromatic-optical contrasts?

What do they point out?

Is there an intercom system? No

Height cm

Obstacles: 2,5 cm threshold.

Type of entrance door opening: revolving

Conditions: manual

Notes:

Sidewalk next to the building is accessible. The door is 60 cm wide with manual two wings doors.
Service entrance leads to the elevator on the ground floor. To access this second door, staff assistance is required.

LEVEL OF SATISFACTION OF NEEDS

Family with children in stroller/pram	Partial
Obese person or pregnant woman	Partial
Elderly, lame, heart patient	Partial
Deaf or hearing impaired person	Good
Blind or visually impaired person	Partial
Person in wheel-chair with companion	Partial
Person in wheel-chair alone	Partial

0003

CARD DB_RECEPTION

HOTEL CELLAI

Function noted: hotel

Counter height, cm 110

Narrowest passage, cm

Steps? No

How many grouped together?

How many isolated?

Presence of obstacles for mobility? No

Yes, what are they :

Systems for dialogue, useful information: Verbal

Notes:

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Partial

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Partial

HOTEL CELLAI

Type: hotel

Number - Name: 324

Situated on floor: third

Type of room: Double
Twin

Anti-allergenic room? No

Yes:

The room is: No smoking

Width of entrance door cm 90

Internal door, cm

Other:

Is there sufficient space for wheel-chair rotation ? Yes

Other:

Narrowest passage, cm 60

Description: between the wall and the bed

Presence of carpeting? Yes

Are there internal stairs? No

Where?

Is it possible to move the bed? Yes

Bed height, cm 52

Is it possible to modify bed height? No

from cm to cm

Is it possible to move the furniture? Yes

Is there a bathroom in the room? Yes

Bath on the floor at a distance of mt

Is there a telephone? Yes

Alarm system: yes, acoustic

Are there obstacles along the passageway from the room to the emergency exit ? Yes

Which? Trunk on the door entrance, a lot of furnishing in the internal pathways.

Where do the escape routes lead to: safe static accessible place

Notes: The room is very wide.
Accessible rooms numbers are: 114, 219, 301, 320, 324, 414 similar in disposition and dimensions.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies	Scarce
Family with children in stroller/pram	Good
Obese person or pregnant woman	Good
Elderly, lame, heart patient	Good
Deaf or hearing impaired person	Partial
Blind or visually impaired person	Good
Person in wheel-chair with companion	Good
Person in wheel-chair alone	Good

HOTEL CELLAI

Type: hotel

Number - Name: 320

Situated on floor: third

Type of room: Double

Anti-allergenic room? No

Yes:

The room is: No smoking

Width of entrance door cm 83

Internal door, cm

Other:

Is there sufficient space for wheel-chair rotation ? No

Other: 148*139

Narrowest passage, cm 50

Description: between the desk and the table

Presence of carpeting? Yes

Are there internal stairs? No

Where?

Is it possible to move the bed? No

Bed height, cm 52

Is it possible to modify bed height? No

from cm to cm

Is it possible to move the furniture? No

Is there a bathroom in the room? Yes

Bath on the floor at a distance of mt

Is there a telephone? Yes

Alarm system: yes, acoustic

Are there obstacles along the passageway from the room to the emergency exit ? Yes

Which?

Where do the escape routes lead to: safe static accessible place

Notes: The room is not very wide.

Accessible rooms numbers are: 114, 219, 301, 320, 324, 414 similar in disposition and dimensions.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies Scarce

Family with children in stroller/pram Partial

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Partial

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Partial

CARD DB_WC/BATHROOM/RESTROOM**HOTEL CELLAI**

Service:

In: room

Number - name: 320

Situated on floor: third

Anteroom? No

Entrance door, cm

Basin?

Type:

Type of basin faucet:

Space in front of the faucet, cm

Presence of: Bathroom

Entrance door, cm 95

Basin? Yes

Type: suspended

Type of basin faucet: knob

Space in front of the faucet, cm 140

Type of toilet: floor toilet

Space in front of toilet, cm 117

Space to the right of toilet, cm 45

Space to the left of toilet, cm 92

Height of toilet, cm 53

Bidet? No

Handles to the right of toilet? No

Handles to the left of toilet? No

Shower? No

Type of shower:

Shower provided with seat?

Type:

Shower provided with handles?

Bathtub? Yes

Type: Bathtub with shower

Provided with internal seat? No

Provided with handles? No

Provided with lifter? No

Model:

Notes: The bathroom has a double wing door without door holder with a little rigid elastic. It's wide enough for wheelchair mobility.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Good

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Partial

Person in wheel-chair alone Scarce

CARD DB_WC/BATHROOM/RESTROOM**HOTEL CELLAI**

Service:

In: room

Number - name: 324

Situated on floor: third

Anteroom? No

Entrance door, cm

Basin?

Type:

Type of basin faucet:

Space in front of the faucet, cm

Presence of: Bathroom

Entrance door, cm 88

Basin? Yes

Type: on a column

Type of basin faucet: knob

Space in front of the faucet, cm 170

Type of toilet: floor toilet

Space in front of toilet, cm 100

Space to the right of toilet, cm 53

Space to the left of toilet, cm 30

Height of toilet, cm 44

Bidet? No

Handles to the right of toilet? Yes

Handles to the left of toilet? Yes

Shower? No

Type of shower:

Shower provided with seat?

Type:

Shower provided with handles?

Bathtub? Si
Yes

Type: Bathtub with shower

Provided with internal seat? No

Provided with handles? Yes

Provided with lifter?

Model:

Notes: The bathroom has a double wing door without door holder with a little rigid elastic. There are grabs but they are not folding.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Partial

CARD DB_WC/BATHROOM/RESTROOM**HOTEL CELLAI**

Service: only one

In: public

Number - name:

Situated on floor: ground

Anteroom? Yes

Entrance door, cm 100

Basin? Yes

Type: on a column

Type of basin faucet: manopola

Space in front of the faucet, cm 110

Presence of: Restroom

Entrance door, cm 87

Basin? Yes

Type: on a column

Type of basin faucet: knob

Space in front of the faucet, cm 95

Type of toilet: floor toilet

Space in front of toilet, cm 95

Space to the right of toilet, cm 31

Space to the left of toilet, cm 80

Height of toilet, cm 43

Bidet? No

Handles to the right of toilet? No

Handles to the left of toilet? No

Shower? No

Type of shower:

Shower provided with seat?

Type:

Shower provided with handles?

Bathtub? No

Type:

Provided with internal seat?

Provided with handles?

Provided with lifter?

Model:

Notes: The public bathroom is situated near the conference room and it's accessible through a not chromatically marked ramp, due to the white sloped pavement.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Good

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Good

Blind or visually impaired person Partial

Person in wheel-chair with companion Good

Person in wheel-chair alone Partial

CARD DB_ROOMS/SERVICES

0003

HOTEL CELLAI

Type: hotel

Name of room: Billiard room

Hall / service is located on floor: ground floor

Number of seats n.

Entrance, cm 100

Narrowest passage, cm

Is there sufficient space for wheel-chair rotation? Yes

Are there reserved seats? no

How many?

Relations with the public are:

Height of buffet, cm

Height of counter, cm

Notes: The hall is a little narrow, there are furnishings that could limit mobility.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Partial

Obese person or pregnant woman Partial

Elderly, lame, heart patient Good

Deaf or hearing impaired person Good

Blind or visually impaired person Partial

Person in wheel-chair with companion Partial

Person in wheel-chair alone Scarce

CARD DB_ROOMS/SERVICES

0003

HOTEL CELLAI

Type: hotel

Name of room: breakfast room

Hall / service is located on floor: ground floor

Number of seats n. 54

Entrance, cm 120

Narrowest passage, cm

Is there sufficient space for wheel-chair rotation? Si

Are there reserved seats? no

How many?

Relations with the public are:

Height of buffet, cm 76-82

Height of counter, cm

Notes: The hall is a little narrow, there are furnishings that could limit mobility.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies Partial

Person with allergies Good

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Good

CARD DB_ROOMS/SERVICES

0003

HOTEL CELLAI

Type: hotel

Name of room: bar

Hall / service is located on floor: ground floor

Number of seats n. 26

Entrance, cm 119

Narrowest passage, cm

Is there sufficient space for wheel-chair rotation? Yes

Are there reserved seats? no

How many?

Relations with the public are:

Height of buffet, cm

Height of counter, cm 95

Notes: Wide hall, comfortable and warm. The space under the table is 67 cm high.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies Partial

Person with allergies Good

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Good

CARD DB_ROOMS/SERVICES

0003

HOTEL CELLAI

Type: hotel

Name of room: conference room

Hall / service is located on floor: ground floor

Number of seats n. 12

Entrance, cm 90

Narrowest passage, cm

Is there sufficient space for wheel-chair rotation? Yes

Are there reserved seats? no

How many?

Relations with the public are:

Height of buffet, cm

Height of counter, cm 95

Notes: Wide hall, comfortable and warm. The space under the table is 68 cm high.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies Partial

Person with allergies Good

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Good

Present? Yes

Is a service key necessary? No

Where is the key kept ?

Instructions for use:

Connected from: ground

To: fourth

Interior width, cm 104

Entrance, cm 63

Interior depth, cm 84

Entrance type: Single door

Interior push-button panel: Normal

Maximum height of cm 150

Acoustic signal of arrival at floor: Not present

Is an intercom or emergency button present? Yes

Height, cm 150

Notes: The lift is located near the second entrance reserved to disabled outside of the hotel. To access the lift, ask the staff.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Scarce

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Partial

Blind or visually impaired person Partial

Person in wheel-chair with companion Good

Person in wheel-chair alone Partial

Present? Yes

Is a service key necessary? No

Where is the key kept ?

Instructions for use:

Connected from: ground

To: fourth

Interior width, cm 97

Entrance, cm 80

Interior depth, cm 94

Entrance type: Single door

Interior push-button panel: In Braille and relief

Maximum height of cm 125

Acoustic signal of arrival at floor: Acoustic

Is an intercom or emergency button present? Yes

Height, cm 125

Notes:

The lift is inside of the hotel. There are five steps to overcome to access the lift.

LEVEL OF SATISFACTION OF NEEDS

- Person with food allergies

Person with allergies

Family with children in stroller/pram Partial

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Partial

Blind or visually impaired person Good

Person in wheel-chair with companion Partial

Person in wheel-chair alone Scarce

CARD DB_STAIR

0003

HOTEL CELLAI

Are stairs present? Yes

Width, cm

Flight of stairs n.

Total number of stairs n.

Connecting from:

To:

Is there a hand rail:

Notes: Internal stairway.

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Partial

Blind or visually impaired person Scarce

Person in wheel-chair with companion

Person in wheel-chair alone