

CARD DB GENERAL INFORMATION

Recording date: 2/3/09

Type Hotel

Name HOTEL LEONARDO DA VINCI

Category 3 STARS

Address VIA GUIDO MONACO

Town FIRENZE

Province FIRENZE

Telephone 055-357751

Fax 055-352563

E-mail info@leonardodavincihotel.net

Internet www.leonardodavincihotel.net

Hours of public service 24 hours

Closing day or closing time NO

Person in charge of: Heitor Paiva

Qualification Executive Manager

Position town center

Surrounding land level roads

Height of place a.s.l., mt. 50

- Spoken languages?:
- Italian
- English
- Spanish
- French
- Portuguese

- Services offered by the structure:
- Restaurant
- Convention rooms
- Waiting room
- Breakfast room
- TV room
- Sauna
- Fitness room

Transport towards structure

Urban bus

Distance from nearest stop, mt.

100

Transport towards structure

Distance from nearest stop, mt.

Are there generic plans of the structure? No

Are there tactile plans of the structure? No

Are there generic brochures of the structure? Yes

Are there printed information brochures in Braille? No

Information availability on: No support

Available transport for internal or external mobility:

None

the shop in front of the hotel rents wheelchairs

The following payment is accepted

All

# CARD DB\_ACCOMODATION STRUCTURE

0009

**HOTEL LEONARDO DA VINCI**

Period when open: Annual

Service method: Half Board

Is Room Service available? Yes

Are rooms declared accessible by the manager? Yes

How many? 2

Are rooms declared anti-allergic by the manager? No

How many?

There are menus for: Diabetics  
People with allergies  
Kidney suffers  
Coeliac  
Children  
The elderly

Which public structures are present in the town or in the town closest by?

Health Structures within about 5 km

**Service structures in the area**

**Tourist information office**

**Service structures in the provincial area**

**Are there emergency exits? Yes**

**The alarm is: Visual and Acoustic**

**Notes:** In case of call from international cellphone all phone numbers require international prefix 0039.

- Hospital: Ospedale di S.M. Nuova P.za S.M. Nuova, 1 tel. 055-27.58.1
- First Aid: Misericordia di Firenze P.za Duomo, 20 tel. 055-23939
- Eyes Surgeon: Oculista Laganà via dei Martelli, 8 tel. 055-23.81.699
  
- Touristic Informations: P.za della Stazione tel. 055-212245
- Touristic Informations: Borgo Santa Croce, 29 tel. 055-23.40.444
- Touristic Informations: Via Manzoni, 16 tel. 055-23.32.0
  
- Car Repair special equipment: Autofficina, via Mariti, 53 tel 055-35.18.93
- Special equipment car repair and rental - Autofficina Poggesi,  
via di Collodi, 10/20 tel. 339-40.40.759
- Car Rental: Autonoleggio Auto via de' Cattani, 23 tel. 055-30.24.436
- Bike and scooter rental: via S. Zanobi, 120/r tel. 055-48.89.92

# CARD DB\_RESTAURANT

0009

**HOTEL LEONARDO DA VINCI**

Is it inside another structure? No

Which one:

Are smoking areas available? No

Type of tables:

The space below the table is cm 72

Is there table service? Yes

Is there self-service? No

Height of buffet, cm 100

Narrowest passage cm

There are menus for:

Is the personnel able to give information regarding the food served? Yes

Does the menu offer a description in Braille? No

**Are there direction signs?** No

**Is there a restroom?** Yes

**Are there emergency exits?** Yes

**The alarm device is:**

**Notes:** Balcony is 72 cm height.

CARD DB\_PARKING LOT / CAR PARK

HOTEL LEONARDO DA VINCI

Type of parking lot: Parking lot reserved for clients  
Paying  
Uncovered

Is there an intercom system? Yes

Type? bell

Height, cm 130

Obstacles:

The distance is mt 30

Type of path: pedonale

Type of pavement: pavimentato

Possible difficulties encountered along the way:

Is it connected directly to the structure? Yes

By: Pedestrian walkway

Are there direction signs? Yes

Are tactile guides present? No

**Notes:** The hotel has an agreement with a paying garage parking service that picks-up/return the car on demand.  
Daily fee 15 euro.

LEVEL OF SATISFACTION OF NEEDS

Family with children in stroller/pram	Good
Obese person or pregnant woman	Good
Elderly, lame, heart patient	Good
Deaf or hearing impaired person	Good
Blind or visually impaired person	Good
Person in wheel-chair with companion	Good
Person in wheel-chair alone	Good

# CARD DB\_ENTRANCE

0009

## HOTEL LEONARDO DA VINCI

Entrance: Principal

Width, cm 120

Are there stairs? No

How many?

Are they chromatically marked?

Are there any aids to bypass the stairs?

Which?

Are there chromatic-optical contrasts?

What do they point out?

Is there an intercom system? bell

Height cm 124

Obstacles:

Type of entrance door opening: revolving

Conditions: automatic



**Notes:**

### **LEVEL OF SATISFACTION OF NEEDS**

**Family with children in stroller/pram**

**Obese person or pregnant woman**

**Elderly, lame, heart patient**

**Deaf or hearing impaired person**

**Blind or visually impaired person**

**Person in wheel-chair with companion**

**Person in wheel-chair alone**

# CARD DB\_ENTRANCE

0009

## HOTEL LEONARDO DA VINCI

Entrance: Secondary

Width, cm 126

Are there stairs? No

How many?

Are they chromatically marked?

Are there any aids to bypass the stairs?

Which?

Are there chromatic-optical contrasts?

What do they point out?

Is there an intercom system? No

Height cm

Obstacles:

Type of entrance door opening: revolving

Conditions: manual

**Notes:**

The door is mainly for luggage entrance but it's used as well as entrance for disabled people. The internal threshold has 15% slope and 60 cm long.

**LEVEL OF SATISFACTION OF NEEDS**

Family with children in stroller/pram	Good
Obese person or pregnant woman	Partial
Elderly, lame, heart patient	Partial
Deaf or hearing impaired person	Good
Blind or visually impaired person	Partial
Person in wheel-chair with companion	Good
Person in wheel-chair alone	Good

0009

## CARD DB\_RECEPTION

### HOTEL LEONARDO DA VINCI

Function noted: hotel

Counter height, cm 120

Narrowest passage, cm

Steps? No

How many grouped together?

How many isolated?

Presence of obstacles for mobility? No

Yes, what are they :

Systems for dialogue, useful information: Verbal

**Notes:**

## LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Partial

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Partial

0009

# CARD DB\_INTERNAL PATHWAYS

## HOTEL LEONARDO DA VINCI

### MOBILITY OR DIRECTION PROBLEMS NOTICED ON THE PATHWAYS

**FROM:**

Elevator entrance

**TO:**

Room 103

**PROBLEMS?**

**Type of obstacle:**

Connection ramp

**Notes:**

### LEVEL OF SATISFACTION OF NEEDS

Family with children in stroller/pram	Good
Obese person or pregnant woman	Partial
Elderly, lame, heart patient	Partial
Deaf or hearing impaired person	Partial
Blind or visually impaired person	Partial
Person in wheel-chair with companion	Good
Person in wheel-chair alone	Good

Present? Yes

Is a service key necessary? No

Where is the key kept ?

Instructions for use:

Connected from: basement -1

To: fourth

Interior width, cm 90

Entrance, cm 79

Interior depth, cm 174

Entrance type: Double front door

Interior push-button panel: In Braille and relief

Maximum height of cm 121

Acoustic signal of arrival at floor: Acoustic and visual

Is an intercom or emergency button present? Yes

Height, cm 121

Notes:

LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram

Obese person or pregnant woman

Elderly, lame, heart patient

Deaf or hearing impaired person

Blind or visually impaired person

Person in wheel-chair with companion

Person in wheel-chair alone

# CARD DB\_STAIR

0009

## HOTEL LEONARDO DA VINCI

Are stairs present? Yes

Width, cm 120

Flight of stairs n. 2

Total number of stairs n. 60

Connecting from: basement -1

To: fourth

Is there a hand rail: To the right

**Notes:** The stairway are inside of the hotel and covered with carpet. Those of the basement are illuminated.

### LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Partial

Blind or visually impaired person Partial

Person in wheel-chair with companion

Person in wheel-chair alone



0009

## CARD DB\_RAMP

### HOTEL LEONARDO DA VINCI

Are one or more ramps present? Yes

How many? 1

Width, cm 126

Length, cm 60

Surpassed difference in height, cm 10

Gradient: 16,7 %

Connected from: external square

to: area inside of the structure

Equipped with handrail : No

**Notes:** The ramp is located on the secondary hotel entrance, normally used for luggage and disabled.

#### LEVEL OF SATISFACTION OF NEEDS

Family with children in stroller/pram Good

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Partial

Blind or visually impaired person Partial

Person in wheel-chair with companion Good

Person in wheel-chair alone Partial

**CARD DB\_BEDROOM****HOTEL LEONARDO DA VINCI**

Type: hotel

Number - Name: 103

Situated on floor: first

Type of room: Twin

Anti-allergenic room? No

Yes:

The room is: No smoking

Width of entrance door cm 84

Internal door, cm

Other:

Is there sufficient space for wheel-chair rotation ? Yes

Other:

Narrowest passage, cm 65

Description: pathway between the wall and the bed

Presence of carpeting? No

Are there internal stairs? No

Where?

Is it possible to move the bed? Yes

Bed height, cm 55

Is it possible to modify bed height? No

from cm to cm

Is it possible to move the furniture? No

Is there a bathroom in the room? Yes

Bath on the floor at a distance of mt

Is there a telephone? Yes

Alarm system: no

Are there obstacles along the passageway from the room to the emergency exit ? No

Which?

Where do the escape routes lead to: safe static accessible place

**Notes:** On the pathway between the lift and the room, there is a conjunction on the pavement made of a ramp: dangerous because not visible.

Accessible rooms numbers are: 103, 203 similar in disposition and dimensions.

## LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies	Partial
Family with children in stroller/pram	Good
Obese person or pregnant woman	Good
Elderly, lame, heart patient	Good
Deaf or hearing impaired person	Partial
Blind or visually impaired person	Partial
Person in wheel-chair with companion	Good
Person in wheel-chair alone	Partial

**CARD DB\_WC/BATHROOM/RESTROOM****HOTEL LEONARDO DA VINCI**

Service:

In: room

Number - name: 103

Situated on floor: first

**Anteroom?** No

Entrance door, cm

Basin?

Type:

Type of basin faucet:

Space in front of the faucet, cm

**Presence of:** Bathroom  
Bagno

Entrance door, cm 84

Basin? Yes

Type: suspended

Type of basin faucet: lever

Space in front of the faucet, cm 152

Type of toilet: floor toilet

Space in front of toilet, cm 20

Space to the right of toilet, cm 20

Space to the left of toilet, cm 90

Height of toilet, cm 45-47

Bidet? No

Handles to the right of toilet? No

Handles to the left of toilet? Yes

Shower? Yes  
Si

Type of shower: on floor

Shower provided with seat? No

Type:

Shower provided with handles? Yes

Bathtub? No

Type:

Provided with internal seat?

Provided with handles?

Provided with lifter?

Model:

Notes:

## LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Partial

Obese person or pregnant woman Partial

Elderly, lame, heart patient Partial

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Partial

**CARD DB\_WC/BATHROOM/RESTROOM****HOTEL LEONARDO DA VINCI**

Service:

In: public

Number - name:

Situated on floor: basement -1

**Anteroom?** No

Entrance door, cm

Basin?

Type:

Type of basin faucet:

Space in front of the faucet, cm

**Presence of:** Bathroom

Entrance door, cm 74

Basin? Yes

Type: suspended

Type of basin faucet: infrared

Space in front of the faucet, cm 113

Type of toilet: floor toilet

Space in front of toilet, cm 82

Space to the right of toilet, cm 86

Space to the left of toilet, cm 20

Height of toilet, cm 45-47

Bidet? No

Handles to the right of toilet? Yes

Handles to the left of toilet? No

Shower? No

Type of shower:

Shower provided with seat?

Type:

Shower provided with handles?

Bathtub? No

Type:

Provided with internal seat?

Provided with handles?

Provided with lifter?

Model:

**Notes:** The public bathroom is near the breakfast/restaurant room.

## LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram      Scarce

Obese person or pregnant woman      Partial

Elderly, lame, heart patient      Partial

Deaf or hearing impaired person      Good

Blind or visually impaired person      Good

Person in wheel-chair with companion      Good

Person in wheel-chair alone      Partial

**CARD DB\_WC/BATHROOM/RESTROOM****HOTEL LEONARDO DA VINCI**

Service:

In: public

Number - name:

Situated on floor: basement -1

**Anteroom?** No  
Yes

Entrance door, cm 80

Basin? Yes

Type: suspended

Type of basin faucet: pedal

Space in front of the faucet, cm 96

**Presence of:** Bathroom

Entrance door, cm 85

Basin? Yes

Type: suspended

Type of basin faucet: infrared

Space in front of the faucet, cm 140

Type of toilet: floor toilet

Space in front of toilet, cm 50

Space to the right of toilet, cm 140

Space to the left of toilet, cm 38

Height of toilet, cm 45-47

Bidet? No  
Yes

Handles to the right of toilet? No

Handles to the left of toilet? No



Shower? No

Type of shower:

Shower provided with seat?

Type:

Shower provided with handles?

Bathtub? No

Type:

Provided with internal seat?

Provided with handles?

Provided with lifter?

Model:

**Notes:** The public bathroom is near the breakfast/restaurant room.

## LEVEL OF SATISFACTION OF NEEDS

Person with food allergies

Person with allergies

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Partial

# CARD DB\_ROOMS/SERVICES

0009

## HOTEL LEONARDO DA VINCI

Type: hotel

Name of room: Breakfast room

Hall / service is located on floor: basement -1

Number of seats n. 50+32 sgabelli

Entrance, cm 274

Narrowest passage, cm

Is there sufficient space for wheel-chair rotation? Yes

Are there reserved seats? no

How many?

Relations with the public are:

Height of buffet, cm 100

Height of counter, cm 117

**Notes:** Breakfast room and restaurant room are accessible through stairs or lift.

## LEVEL OF SATISFACTION OF NEEDS

Person with food allergies Good

Person with allergies Good

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Good

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Good

# CARD DB\_ROOMS/SERVICES

0009

## HOTEL LEONARDO DA VINCI

Type: hotel

Name of room: Conference room, meeting room

Hall / service is located on floor: basement -1

Number of seats n. 34

Entrance, cm 112

Narrowest passage, cm

Is there sufficient space for wheel-chair rotation? Yes

Are there reserved seats? no

How many?

Relations with the public are:

Height of buffet, cm 100

Height of counter, cm 117

**Notes:** Breakfast room and restaurant room are accessible through stairs or lift.

Space under the table is 77 cm high.

## LEVEL OF SATISFACTION OF NEEDS

Person with food allergies Good

Person with allergies Good

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Partial

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Good

# CARD DB\_ROOMS/SERVICES

0009

## HOTEL LEONARDO DA VINCI

Type: hotel

Name of room: Generic room

Hall / service is located on floor: first

Number of seats n. 26

Entrance, cm 150

Narrowest passage, cm

Is there sufficient space for wheel-chair rotation? Yes

Are there reserved seats? no

How many?

Relations with the public are:

Height of buffet, cm 100

Height of counter, cm 117

**Notes:** The hall is used as relax room, entertainment and internet point.

Space under the table is 66 cm high.

## LEVEL OF SATISFACTION OF NEEDS

Person with food allergies Good

Person with allergies Good

Family with children in stroller/pram Good

Obese person or pregnant woman Good

Elderly, lame, heart patient Good

Deaf or hearing impaired person Partial

Blind or visually impaired person Good

Person in wheel-chair with companion Good

Person in wheel-chair alone Good